

CERTIFICATE OF MAINTENANCE

FIRE EQUIPMENT

PREMISES	Almac Clinical B 10 A+B 9 Charlestown Road Seagoe Portadown Armagh Northern Ireland
ENGINEER	Paul English
CERTIFICATE NUMBER:	C-00277

Quantity	Model	Details
19	Foam	8 Basic Service 10 Extended Service 1 Condemned and replaced
9	CO2	7 Basic Service 1 Condemned and replaced 1 Overhaul
3	Powder	3 Basic Service
1	Fire Blanket	1 Basic Service

Recommendations

No.	Type	Non-Compliance	Recommendation/New equipment
-----	------	----------------	------------------------------

Date of Issue:	13/02/2020
----------------	------------

The Certificate is to state that the firefighting equipment sited within the named premises has been inspected in accordance with BS5306-3:2017 or I.S 291:2015 Equivalent Testing and refilling completed will have been carried out in accordance with BS5306-9:2015 or I.S 291:2015 Equivalent. Siting of the firefighting equipment meets the requirements of BS5306-8:2012 or I.S 291:2015 Equivalent and any future amendments.

Remedial actions if not completed at the time of service will be noted below on this certification.