

## CERTIFICATE OF MAINTENANCE

### FIRE EQUIPMENT

<b>PREMISES</b>	Almac Clinical B 10 A+B 9 Charlestown Road Seagoe Portadown Armagh Northern Ireland
<b>ENGINEER</b>	Jeff Dodds
<b>CERTIFICATE NUMBER:</b>	C-00072

Quantity	Model	Details
16	Foam	16 Basic Service
8	CO2	8 Basic Service
3	Powder	2 Service Exchange 1 Basic Service
1	Fire Blanket	1 Basic Service

### Recommendations

No.	Type	Non-Compliance	Recommendation/New equipment
Date of Issue:	21/02/2019		

This certificate confirms that the maintenance service of your fire equipment listed above has been carried out in accordance with national standards BS5306: Part 3 and Part 8: 2017 (Extinguishers), BS5839 (Fire Alarms), BS5306: Part 1 1976 (Hose Reels) BS9990 (Dry/Wet Risers & Hydrants) BS5266 (Emergency Lighting).

Next service due in 12 months