

Fire Extinguisher Certificate of Inspection

Customer Name & Address	Almac Group - Almac Clinical B11 20 Seagoe Industrial Estate BT63 5QD				
Engineer:	Paul English	Job Number:	J-03827	Order Number:	
Certificate Number:	814	Date:	25/02/2021		

Quantity	Model	Details
3	Powder	1 Basic Service
9	Foam	8 Basic Service 1 Extended Service
8	CO2	8 Basic Service
0	Fire Blanket	
0	Water	
0	F Class	

Extinguisher	Serial No.	Location	Type	Size	Action
001 - Foam - Main entrance	AB11001	Main entrance	Foam	6	Basic Service
002 - CO2 - Main Entrance	AB11002	Main Entrance	CO2	5	Basic Service
003 - Foam - Vault-Ground Floor	AB11003	Vault-Ground Floor	Foam	6	Basic Service
004 - CO2 - Vault-Ground Floor	AB11004	Vault-Ground Floor	CO2	5	Basic Service
005 - Foam - Vault-1st Floor	AB11005	Vault-1st Floor	Foam	6	Basic Service
006 - Foam - Vault 2nd Floor	AB11006	Vault 2nd Floor	Foam	6	Basic Service
007 - Powder - Warehouse Fire Exit	AB11007	Warehouse Fire Exit	Powder	9	Service Exchange
008 - Powder - Cold Room Fire Exit 1	AB11008	Cold Room Fire Exit 1	Powder	9	Service Exchange
009 - Powder - Cold Room Fire Exit 2	AB11009	Cold Room Fire Exit 2	Powder	6	Basic Service
010 - Foam - Rear Yard - Box @ Fuel Tank	AB11010	Rear Yard - Box @ Fuel Tank	Foam	9	Basic Service
011 - CO2 - Comms Room	AB11011	Comms Room	CO2	5	Basic Service
012 - CO2 - Switch Room	AB11012	Switch Room	CO2	5	Basic Service
013 - Foam - Sprinkler Room	AB11013	Sprinkler Room	Foam	6	Basic Service
014 - Foam - Up Ladder	AB11014	Up Ladder	Foam	6	Basic Service
015 - CO2 - Sprinkler room	AB11015	Sprinkler room	CO2	2	Basic Service
016 - CO2 - Up ladder/ 1	AB11016	Up ladder/ 1	CO2	5	Basic Service
017 - CO2 - Up ladder	AB11017	Up ladder	CO2	5	Basic Service
018 - Foam - Up Ladder	AB11018	Up Ladder	Foam	6	Basic Service
019 - Foam - Cold room Lobby	AB11019	Cold room Lobby	Foam	6	Extended Service
020 - CO2 - Cold Room Lobby	AB11020	Cold Room Lobby	CO2	2	Basic Service

General Comments

Special Remarks

**FireHow Limited**

Suite 10 Avonmore House

15 Church Square

Banbridge BT32 4AP

t 028406 48444 m 44 07846633129

e: colin.bickerstaff@firehow.co.uk

w: www.firehow.co.uk

Company Registration No. NI 648838**VAT No.** 280425024

I/We have inspected and serviced as necessary to BS5306-3 (Uk) and IS 291 (ROI), the fire extinguishers on this certificate.
These were left in good working order, except where indicated on this certificate.
Please Note Comments Listed Under Special Remarks.

Customer Signature:		Inspector's Signature:		Time In:	10:10
Customer Print Name:	Orla McGrath	Print Name:	Paul English	Time Out	12:01
Position:	Supervisor				

FIREHØW

FireHow Limited

Suite 10 Avonmore House

15 Church Square

Banbridge BT32 4AP

t 028406 48444 m 44 07846633129

e: colin.bickerstaff@firehow.co.uk

w: www.firehow.co.uk

Company Registration No. NI 648838

VAT No. 280425024

Photos

