

Fire Extinguisher Certificate of Inspection

Customer Name & Address	Almac Group - Almac Clinical B14B 20 Seagoe Industrial Estate BT63 5QD				
Engineer:	Paul English	Job Number:	J-02982	Order Number:	
Certificate Number:	518	Date:	10/05/2021		

Quantity	Model	Details
0	Powder	
9	Foam	9 Basic Service
13	CO2	13 Basic Service
1	Fire Blanket	1 Basic Service
0	Water	
0	F Class	

Extinguisher	Serial No.	Location	Type	Size	Action
001 - Foam - Entrance	AB14B001	Entrance	Foam	6	Basic Service
002 - CO2 - Entrance	AB14B002	Entrance	CO2	2	Basic Service
003 - Foam - 1st Floor Office Area	AB14B003	1st Floor Office Area	Foam	6	Basic Service
004 - CO2 - 1st Floor Office Area	AB14B004	1st Floor Office Area	CO2	2	Basic Service
005 - Foam - @ Fire Exit	AB14B005	@ Fire Exit	Foam	6	Basic Service
006 - CO2 - @ Fire Exit	AB14B006	@ Fire Exit	CO2	2	Basic Service
007 - Foam - Side wall	AB14B007	Side wall	Foam	6	Basic Service
008 - CO2 - Side Wall	AB14B008	Side Wall	CO2	2	Basic Service
009 - CO2 - The E learning suite	AB14B009	The E learning suite	CO2	2	Basic Service
010 - Foam - O/S Boiler Room	AB14B010	O/S Boiler Room	Foam	6	Basic Service
011 - CO2 - O/S Boiler Room	AB14B011	O/S Boiler Room	CO2	2	Basic Service
012 - Foam - Boiler Room	AB14B012	Boiler Room	Foam	6	Basic Service
013 - CO2 - Boiler Room	AB14B013	Boiler Room	CO2	2	Basic Service
014 - CO2 - Server Room code 423	AB14B014	Server Room code 423	CO2	5	Basic Service
015 - CO2 - O/S Switchroom	AB14B015	O/S Switchroom	CO2	2	Basic Service
016 - CO2 - Corridor	AB14B016	Corridor	CO2	2	Basic Service
017 - Foam - Corridor @ Fire Exit	AB14B017	Corridor @ Fire Exit	Foam	6	Basic Service
018 - Foam - O/S Canteen	AB14B018	O/S Canteen	Foam	6	Basic Service
019 - CO2 - O/S Canteen	AB14B019	O/S Canteen	CO2	2	Basic Service
020 - CO2 - Canteen	AB14B020	Canteen	CO2	2	Basic Service
021 - Fire Blanket - Canteen	AB14B021	Canteen	Fire Blanket	0	Basic Service
022 - Foam - Basement lift code 4507	AB14B022	Basement lift code 4507	Foam	6	Basic Service
023 - CO2 - Basement	AB14B023	Basement	CO2	2	Basic Service

General Comments

Special Remarks

FIREHØW

FireHow Limited

Suite 10 Avonmore House

15 Church Square

Banbridge BT32 4AP

t 028406 48444 m 44 07846633129

e: colin.bickerstaff@firehow.co.uk

w: www.firehow.co.uk

Company Registration No. NI 648838

VAT No. 280425024

--

I/We have inspected and serviced as necessary to BS5306-3 (UK) and IS 291 (ROI), the fire extinguishers on this certificate. These were left in good working order, except where indicated on this certificate. Please Note Comments Listed Under Special Remarks.

Customer Signature:		Inspector's Signature:		Time In:	12:05
Customer Print Name:	Lynn Ryan	Print Name:	Paul English	Time Out	12:38
Position:	Manager				

FIREHØW

FireHow Limited

Suite 10 Avonmore House

15 Church Square

Banbridge BT32 4AP

t 028406 48444 m 44 07846633129

e: colin.bickerstaff@firehow.co.uk

w: www.firehow.co.uk

Company Registration No. NI 648838

VAT No. 280425024

Photos

