

CERTIFICATE OF MAINTENANCE

FIRE EQUIPMENT

PREMISES	Almac Clinical B19 20 Seagoe Industrial Estate Craigavon BT63 5QD Northern Ireland
ENGINEER	Colin Bickerstaff
CERTIFICATE NUMBER:	C-00067

Quantity	Model	Details
15	Foam	15 Basic Service
14	CO2	6 Overhaul 9 Basic Service
3	Fire Blanket	3 Basic Service
1	Powder	1 Basic Service

Recommendations

No.	Type	Non-Compliance	Recommendation/New equipment
Date of Issue:		23/01/2019	

This certificate confirms that the maintenance service of your fire equipment listed above has been carried out in accordance with national standards BS5306: Part 3 and Part 8: 2017 (Extinguishers), BS5839 (Fire Alarms), BS5306: Part 1 1976 (Hose Reels) BS9990 (Dry/Wet Risers & Hydrants) BS5266 (Emergency Lighting).

Next service due in 12 months