

## CERTIFICATE OF MAINTENANCE

### FIRE EQUIPMENT

<b>PREMISES</b>	Almac Clinical B1B 20 Seagoe Industrial Estate Craigavon BT63 5QD Northern Ireland
<b>ENGINEER</b>	Colin Bickerstaff
<b>CERTIFICATE NUMBER:</b>	C-00543

Quantity	Model	Details
4	CO2	3 Basic Service 1 Overhaul
7	Foam	1 Condemned and replaced 5 Basic Service
3	Powder	1 Basic Service 2 Service Exchange

### Recommendations

No.	Type	Non-Compliance	Recommendation/New equipment
B1B002	Warehouse entrance	Dent	Replaced with new

Date of Issue:	01/07/2020
----------------	------------

The Certificate is to state that the firefighting equipment sited within the named premises has been inspected in accordance with BS5306-3:2017 or I.S 291:2015 Equivalent Testing and refilling completed will have been carried out in accordance with BS5306-9:2015 or I.S 291:2015 Equivalent. Siting of the firefighting equipment meets the requirements of BS5306-8:2012 or I.S 291:2015 Equivalent and any future amendments.

Remedial actions if not completed at the time of service will be noted below on this certification.