

CERTIFICATE OF MAINTENANCE

FIRE EQUIPMENT

PREMISES	Almac Clinical Unit 18 20 Seagoe Industrial Estate Craigavon BT63 5QD Northern Ireland
ENGINEER	Colin Bickerstaff
CERTIFICATE NUMBER:	C-00544

Quantity	Model	Details
9	Foam	3 Condemned and replaced 4 Extended Service 2 Basic Service
6	CO2	4 Basic Service 2 Overhaul
1	Powder	1 Basic Service

Recommendations

No.	Type	Non-Compliance	Recommendation/New equipment
B18001	Changing fire Exit	Gauge fault	Replaced with new
B18002	side Fire Exit	Almost 20 years old and is due extended service	Replaced with new
B18010	Unit 2 front	Gauge fault	Replaced with new

Date of Issue:	01/07/2020
----------------	------------

The Certificate is to state that the firefighting equipment sited within the named premises has been inspected in accordance with BS5306-3:2017 or I.S 291:2015 Equivalent Testing and refilling completed will have been carried out in accordance with BS5306-9:2015 or I.S 291:2015 Equivalent. Siting of the firefighting equipment meets the requirements of BS5306-8:2012 or I.S 291:2015 Equivalent and any future amendments.

Remedial actions if not completed at the time of service will be noted below on this certification.