

CERTIFICATE OF MAINTENANCE

FIRE EQUIPMENT

PREMISES	Almac Diagnostics MMB2 20 Seagoe Industrial Estate Craigavon BT63 5QD Northern Ireland
ENGINEER	Colin Bickerstaff
CERTIFICATE NUMBER:	C-00101

Quantity	Model	Details
24	Foam	22 Basic Service 2 Extended Service
29	CO2	24 Basic Service 4 Overhaul
14	Fire Blanket	14 Basic Service
6	Powder	4 Basic Service 2 Service Exchange

Recommendations

No.	Type	Non-Compliance	Recommendation/New equipment
Date of Issue:		18/04/2019	

This certificate confirms that the maintenance service of your fire equipment listed above has been carried out in accordance with national standards BS5306: Part 3 and Part 8: 2017 (Extinguishers), BS5839 (Fire Alarms), BS5306: Part 1 1976 (Hose Reels) BS9990 (Dry/Wet Risers & Hydrants) BS5266 (Emergency Lighting).

Next service due in 12 months