

CERTIFICATE OF MAINTENANCE

FIRE EQUIPMENT

PREMISES	Almac Group B23B Almac Group Breagh Drive Carn Industrial Estate Craigavon BT63 5QD Northern Ireland
ENGINEER	Paul English
CERTIFICATE NUMBER:	C-00859

Quantity	Model	Details
3	Foam	3 Basic Service
5	CO2	5 Basic Service
1	Fire Blanket	1 Basic Service

Recommendations

No.	Type	Non-Compliance	Recommendation/New equipment
Date of Issue:		22/09/2020	

The Certificate is to state that the firefighting equipment sited within the named premises has been inspected in accordance with BS5306-3:2017 or I.S 291:2015 Equivalent Testing and refilling completed will have been carried out in accordance with BS5306-9:2015 or I.S 291:2015 Equivalent. Siting of the firefighting equipment meets the requirements of BS5306-8:2012 or I.S 291:2015 Equivalent and any future amendments.

Remedial actions if not completed at the time of service will be noted below on this certification.