

CERTIFICATE OF MAINTENANCE

FIRE EQUIPMENT

PREMISES	Almac Group Security Hub Almac House 20 Seagoe Rd Craigavon Armagh Northern Ireland
ENGINEER	Colin Bickerstaff
CERTIFICATE NUMBER:	C-00103

Quantity	Model	Details
2	Foam	2 Basic Service
2	CO2	2 Basic Service

Recommendations

No.	Type	Non-Compliance	Recommendation/New equipment
-----	------	----------------	------------------------------

Date of Issue:	18/04/2019
----------------	------------

This certificate confirms that the maintenance service of your fire equipment listed above has been carried out in accordance with national standards BS5306: Part 3 and Part 8: 2017 (Extinguishers), BS5839 (Fire Alarms), BS5306: Part 1 1976 (Hose Reels) BS9990 (Dry/Wet Risers & Hydrants) BS5266 (Emergency Lighting).

Next service due in 12 months