

## CERTIFICATE OF MAINTENANCE

### FIRE EQUIPMENT

<b>PREMISES</b>	Almac Group Security Hub Almac House 20 Seagoe Rd Craigavon Armagh Northern Ireland
<b>ENGINEER</b>	Colin Bickerstaff
<b>CERTIFICATE NUMBER:</b>	C-00379

Quantity	Model	Details
2	Foam	2 Basic Service
2	CO2	2 Basic Service

### Recommendations

No.	Type	Non-Compliance	Recommendation/New equipment
Date of Issue:		11/04/2020	

The Certificate is to state that the firefighting equipment sited within the named premises has been inspected in accordance with BS5306-3:2017 or I.S 291:2015 Equivalent Testing and refilling completed will have been carried out in accordance with BS5306-9:2015 or I.S 291:2015 Equivalent. Siting of the firefighting equipment meets the requirements of BS5306-8:2012 or I.S 291:2015 Equivalent and any future amendments.

Remedial actions if not completed at the time of service will be noted below on this certification.