

CERTIFICATE OF MAINTENANCE

FIRE EQUIPMENT

PREMISES	Almac Group DK1 Almac Pharma Services Ireland Finnabair Industrial Estate Dundalk A91 P9KD Ireland
ENGINEER	Colin Bickerstaff
CERTIFICATE NUMBER:	C-00158

Quantity	Model	Details
24	Foam	24 Basic Service
23	CO2	22 Basic Service

Recommendations

No.	Type	Non-Compliance	Recommendation/New equipment
ADK1012	Foam	Missing	9 litre foam
ADK1014	Foam	Missing	9litre foam
ADK1016	Foam	Missing	9litre foam
ADK1020	Foam	Missing	9 litre foam
ADK1013	CO2	Missing	5kg Co2
ADK1015	CO2	Missing	5kg co2
ADK1017	CO2	Missing	5 kg co2
ADK1021	CO2	Missing	5 kg co2

Date of Issue:	09/11/2018
----------------	------------

This certificate confirms that the maintenance service of your fire equipment listed above has been carried out in accordance with national standards BS5306: Part 3 and Part 8: 2017 (Extinguishers), BS5839 (Fire Alarms), BS5306: Part 1 1976 (Hose Reels) BS9990 (Dry/Wet Risers & Hydrants) BS5266 (Emergency Lighting).