

CERTIFICATE OF MAINTENANCE

FIRE EQUIPMENT

PREMISES	Modular lab Finnabair Business Park Dundalk Louth ROI Ireland
ENGINEER	Paul English
CERTIFICATE NUMBER:	C-01610

Quantity	Model	Details
6	Foam	4 Basic Service 2 Extended Service
7	CO2	5 Basic Service 2 Overhaul
4	Fire Blanket	4 Basic Service
2	Powder	1 Basic Service 1 Service Exchange

Recommendations

No.	Type	Non-Compliance	Recommendation/New equipment
-----	------	----------------	------------------------------

Date of Issue:	12/12/2019
----------------	------------

The Certificate is to state that the firefighting equipment sited within the named premises has been inspected in accordance with BS5306-3:2017 or I.S 291:2015 Equivalent Testing and refilling completed will have been carried out in accordance with BS5306-9:2015 or I.S 291:2015 Equivalent. Siting of the firefighting equipment meets the requirements of BS5306-8:2012 or I.S 291:2015 Equivalent and any future amendments.

Remedial actions if not completed at the time of service will be noted below on this certification.