

## CERTIFICATE OF MAINTENANCE

### FIRE EQUIPMENT

<b>PREMISES</b>	Almac Pharma B1 20 Seagoe Industrial Estate Craigavon BT63 5QD Northern Ireland
<b>ENGINEER</b>	Paul English
<b>CERTIFICATE NUMBER:</b>	C-00446

Quantity	Model	Details
60	Foam	48 Basic Service 8 Extended Service 4 Condemned and replaced
70	CO2	62 Basic Service 9 Overhaul
19	Powder	3 Service Exchange 16 Basic Service
8	Fire Blanket	8 Basic Service

### Recommendations

No.	Type	Non-Compliance	Recommendation/New equipment
AB1036	Fire Exit @ Stairs	20 years old	Replaced with new
AB1043	@Lift	Dented	Replaced with new
AB1125	RO Plantroom	20 years old	Replaced with new
AB1150	upstairs to Plantroom 4	Swapped additional CO2 for new foam to provide class A and B coverage in area	Fitted new 6 litre foam

Date of Issue:	12/06/2020
----------------	------------

The Certificate is to state that the firefighting equipment sited within the named premises has been inspected in accordance with BS5306-3:2017 or I.S 291:2015 Equivalent Testing and refilling completed will have been carried out in accordance with BS5306-9:2015 or I.S 291:2015 Equivalent. Siting of the firefighting equipment meets the requirements of BS5306-8:2012 or I.S 291:2015 Equivalent and any future amendments.

Remedial actions if not completed at the time of service will be noted below on this certification.