

## CERTIFICATE OF MAINTENANCE

### FIRE EQUIPMENT

<b>PREMISES</b>	Almac Pharma B12 20 Seagoe Industrial Estate Craigavon BT63 5QD Northern Ireland
<b>ENGINEER</b>	Colin Bickerstaff
<b>CERTIFICATE NUMBER:</b>	C-00084

Quantity	Model	Details
16	Foam	16 Basic Service
8	CO2	2 Overhaul 6 Basic Service

### Recommendations

No.	Type	Non-Compliance	Recommendation/New equipment
Date of Issue:		19/03/2019	

This certificate confirms that the maintenance service of your fire equipment listed above has been carried out in accordance with national standards BS5306: Part 3 and Part 8: 2017 (Extinguishers), BS5839 (Fire Alarms), BS5306: Part 1 1976 (Hose Reels) BS9990 (Dry/Wet Risers & Hydrants) BS5266 (Emergency Lighting).

Next service due in 12 months