

## CERTIFICATE OF MAINTENANCE

### FIRE EQUIPMENT

<b>PREMISES</b>	Almac Pharma B14 20 Seagoe Industrial Estate Craigavon BT63 5QD Northern Ireland
<b>ENGINEER</b>	
<b>CERTIFICATE NUMBER:</b>	C-00109

Quantity	Model	Details
9	Foam	2 Condemned and replaced 5 Basic Service 2 Extended Service
5	CO2	4 Basic Service 1 Overhaul

### Recommendations

No.	Type	Non-Compliance	Recommendation/New equipment
AB14001	Warehouse Entrance	20 years old	Replaced with new
AB14010	Side Fire Exit @ Staitwell	20 years old	Replaced

Date of Issue:	28/05/2019
----------------	------------

This certificate confirms that the maintenance service of your fire equipment listed above has been carried out in accordance with national standards BS5306: Part 3 and Part 8: 2017 (Extinguishers), BS5839 (Fire Alarms), BS5306: Part 1 1976 (Hose Reels) BS9990 (Dry/Wet Risers & Hydrants) BS5266 (Emergency Lighting).

Next service due in 12 months