

CERTIFICATE OF MAINTENANCE

FIRE EQUIPMENT

PREMISES	Almac Pharma B14 20 Seagoe Industrial Estate Craigavon BT63 5QD Northern Ireland
ENGINEER	Colin Bickerstaff
CERTIFICATE NUMBER:	C-00467

Quantity	Model	Details
9	Foam	6 Basic Service 2 Condemned and replaced 1 Extended Service
5	CO2	1 Overhaul 4 Basic Service

Recommendations

No.	Type	Non-Compliance	Recommendation/New equipment
AB14004	Side Fire Exit	20 years old	Replaced with new
AB14012	Canteen Hut	20 years old	Replaced with new

Date of Issue:	19/05/2020
----------------	------------

The Certificate is to state that the firefighting equipment sited within the named premises has been inspected in accordance with BS5306-3:2017 or I.S 291:2015 Equivalent Testing and refilling completed will have been carried out in accordance with BS5306-9:2015 or I.S 291:2015 Equivalent. Siting of the firefighting equipment meets the requirements of BS5306-8:2012 or I.S 291:2015 Equivalent and any future amendments.

Remedial actions if not completed at the time of service will be noted below on this certification.