

CERTIFICATE OF MAINTENANCE

FIRE EQUIPMENT

PREMISES	Almac Pharma 14C 20 Seagoe Industrial Estate Craigavon BT63 5QD Northern Ireland
ENGINEER	
CERTIFICATE NUMBER:	C-00105

Quantity	Model	Details
1	Foam	1 Basic Service
1	CO2	1 Overhaul

Recommendations

No.	Type	Non-Compliance	Recommendation/New equipment
Date of Issue:		28/05/2019	

This certificate confirms that the maintenance service of your fire equipment listed above has been carried out in accordance with national standards BS5306: Part 3 and Part 8: 2017 (Extinguishers), BS5839 (Fire Alarms), BS5306: Part 1 1976 (Hose Reels) BS9990 (Dry/Wet Risers & Hydrants) BS5266 (Emergency Lighting).

Next service due in 12 months