

## CERTIFICATE OF MAINTENANCE

### FIRE EQUIPMENT

<b>PREMISES</b>	Almac Pharma B1A 20 Seagoe Industrial Estate Craigavon BT63 5QD Northern Ireland
<b>ENGINEER</b>	
<b>CERTIFICATE NUMBER:</b>	C-00466

Quantity	Model	Details
8	Foam	7 Basic Service 1 Condemned and replaced
5	CO2	6 Basic Service
4	Fire Blanket	4 Basic Service

### Recommendations

No.	Type	Non-Compliance	Recommendation/New equipment
AB1A005	Lab 4	Gauge fault	Replaced with new

Date of Issue:	06/06/2020
----------------	------------

The Certificate is to state that the firefighting equipment sited within the named premises has been inspected in accordance with BS5306-3:2017 or I.S 291:2015 Equivalent Testing and refilling completed will have been carried out in accordance with BS5306-9:2015 or I.S 291:2015 Equivalent. Siting of the firefighting equipment meets the requirements of BS5306-8:2012 or I.S 291:2015 Equivalent and any future amendments.

Remedial actions if not completed at the time of service will be noted below on this certification.