

CERTIFICATE OF MAINTENANCE

FIRE EQUIPMENT

PREMISES	Almac Pharma B28/29 Charnwood Campus Woodhouse Building 8 Bakewell Street Loughborough Leicestershire LE11 5RB England
ENGINEER	
CERTIFICATE NUMBER:	C-00138

Quantity	Model	Details
104	Foam	105 Basic Service
134	CO2	133 Basic Service
14	Powder	13 Basic Service 1 Condemned & Replace
8	Fire Blanket	8 Basic Service

Recommendations

No.	Type	Non-Compliance	Recommendation/New equipment

Date of Issue:	30/10/2018
----------------	------------

This certificate confirms that the maintenance service of your fire equipment listed above has been carried out in accordance with national standards BS5306: Part 3 and Part 8: 2017 (Extinguishers), BS5839 (Fire Alarms), BS5306: Part 1 1976 (Hose Reels) BS9990 (Dry/Wet Risers & Hydrants) BS5266 (Emergency Lighting).

Next service due in 12 months