

Fire Extinguisher Certificate of Inspection

Customer Name & Address	Almac Group - Almac Pharma B6 20 Seagoe Industrial Estate BT63 5QD				
Engineer:	Colin Bickerstaff	Job Number:	J-03714	Order Number:	
Certificate Number:	1132	Date:	18/01/2021		

Quantity	Model	Details
6	Powder	5 Basic Service
17	Foam	13 Basic Service 4 Extended Service
19	CO2	15 Basic Service
3	Fire Blanket	2 Basic Service
1	Water	1 Basic Service
0	F Class	

Extinguisher	Serial No.	Location	Type	Size	Action
001 - Foam - Entrance	AB6001	Entrance	Foam	6	Basic Service
002 - CO2 - Entrance	AB6002	Entrance	CO2	2	Overhaul
003 - Foam - Formulation Development Fire Exit	AB6003	Formulation Development Fire Exit	Foam	6	Basic Service
004 - Foam - Lab 1 - In Box	AB6004	Lab 1 - In Box	Foam	6	Extended Service
005 - CO2 - LAB 1 - IN BOX	AB6005	LAB 1 - IN BOX	CO2	2	Basic Service
006 - Foam - O/S LAB 7	AB6006	O/S LAB 7	Foam	6	Basic Service
007 - CO2 - O/S LAB 7	AB6007	O/S LAB 7	CO2	2	Basic Service
008 - Foam - Box @ Fire Exit	AB6008	Box @ Fire Exit	Foam	6	Basic Service
009 - CO2 - Box @ Fire Exit	AB6009	Box @ Fire Exit	CO2	2	Basic Service
010 - Foam - Write Up - Fire Exit	AB6010	Write Up - Fire Exit	Foam	6	Basic Service
011 - CO2 - Write Up- Fire Exit	AB6011	Write Up- Fire Exit	CO2	2	Basic Service
012 - Foam - Canteen	AB6012	Canteen	Foam	6	Basic Service
013 - CO2 - Canteen	AB6013	Canteen	CO2	2	Basic Service
014 - Fire Blanket - Canteen	AB6014	Canteen	Fire Blanket	0	
015 - Powder - Analytical lab 4	AB6015	Analytical lab 4	Powder	6	Basic Service
016 - Foam - Analytical Lab 4	AB6016	Analytical Lab 4	Foam	6	Basic Service
017 - CO2 - Analytical lab 4	AB6017	Analytical lab 4	CO2	2	Basic Service
018 - Fire Blanket - Analytical lab 4	AB6018	Analytical lab 4	Fire Blanket	0	Basic Service
019 - Powder - Analytical Lab 5	AB6019	Analytical Lab 5	Powder	6	Basic Service
020 - Foam - Analytical Lab 5	AB6020	Analytical Lab 5	Foam	6	Extended Service
021 - CO2 - Analytical Lab 5	AB6021	Analytical Lab 5	CO2	2	Basic Service
022 - Fire Blanket - Analytical Lab 5	AB6022	Analytical Lab 5	Fire Blanket	0	Basic Service
023 - Foam - Corridor Fire Exit	AB6023	Corridor Fire Exit	Foam	6	Extended Service
024 - CO2 - Corridor Fire Exit	AB6024	Corridor Fire Exit	CO2	2	Basic Service
025 - Foam - Rear Of Building- Formulation	AB6025	Rear Of Building- Formulation	Foam	6	Basic Service
026 - CO2 - Rear of Building Formulation	AB6026	Rear of Building Formulation	CO2	5	Basic Service
027 - CO2 - 1st Floor- service Area	AB6027	1st Floor- service Area	CO2	2	Overhaul


028 - Foam - 1st Floor - Service area	AB6028	1st Floor - Service area	Foam	6	Extended Service
029 - CO2 - Comms Room-Swipe	AB6029	Comms Room-Swipe	CO2	2	Basic Service
030 - CO2 - Plant Room	AB6030	Plant Room	CO2	5	Basic Service
031 - Foam - Plant Room Fire Exit	AB6031	Plant Room Fire Exit	Foam	6	Basic Service
032 - Powder - In Box Rear Of Building	AB6032	In Box Rear Of Building	Powder	9	Basic Service
033 - Powder - In Box Rear Of Building	AB6033	In Box Rear Of Building	Powder	9	Basic Service
034 - Powder - Boiler Room	AB6034	Boiler Room	Powder	6	Basic Service
035 - CO2 - Boiler room	AB6035	Boiler room	CO2	5	Basic Service
036 - Foam - 1St Floor Service area	AB6036	1St Floor Service area	Foam	6	Basic Service
037 - CO2 - 1st Floor Service Area	AB6037	1st Floor Service Area	CO2	2	Overhaul
038 - Foam - Plant Room	AB6038	Plant Room	Foam	6	Basic Service
039 - CO2 - Plant Room	AB6039	Plant Room	CO2	5	Overhaul
042 - Foam - Lobby @ Lab 3	AB6042	Lobby @ Lab 3	Foam	6	Basic Service
043 - CO2 - Lobby @ lab 3	AB6043	Lobby @ lab 3	CO2	2	Basic Service
044 - Water - Boiler house Through Coded door	AB6044	Boiler house Through Coded door	Water	9	Basic Service
045 - Powder - Boiler House Through Coded door	AB6045	Boiler House Through Coded door	Powder	9	Service Exchange
046 - CO2 - next Room into workshop	AB6046	next Room into workshop	CO2	2	Basic Service
047 - Foam - Lab 7 lobby	AB6047	Lab 7 lobby	Foam	6	Basic Service
048 - CO2 - Lab 7 lobby	AB6048	Lab 7 lobby	CO2	2	Basic Service
--	49	Mobile canteen	Co2	2	Basic Service
--	50	Mobile canteen	Co2	2	Basic Service

General Comments

11 x location signs fitted

Special Remarks

I/We have inspected and serviced as necessary to BS5306; parts 3 & 8 2009, the fire extinguishers on this certificate. These were left in good working order, except where indicated on this certificate. Please Note Comments Listed Under Special Remarks.

Customer Signature:		Inspector's Signature:		Time In:	10:01
Customer Print Name:	Lynn Ryan	Print Name:	Colin Bickerstaff	Time Out	11:34
Position:	Manager				

FIREHØW

FireHow Limited

Suite 10 Avonmore House

15 Church Square

Banbridge BT32 4AP

t 028406 48444 m 44 07846633129

e: colin.bickerstaff@firehow.co.uk

w: www.firehow.co.uk

Company Registration No. NI 648838

VAT No. 280425024

Photos

