

CERTIFICATE OF MAINTENANCE

FIRE EQUIPMENT

PREMISES	Almac Siences Almac House Seagoe Portadown Armagh BT63 5UA Northern Ireland
ENGINEER	Paul English
CERTIFICATE NUMBER:	C-00298

Quantity	Model	Details
72	Foam	65 Basic Service 6 Extended Service 1 Condemned and replaced
94	CO2	82 Basic Service 11 Overhaul
38	Fire Blanket	37 Basic Service 1 Condemned and replaced
1	F Class	1 Basic Service
32	Powder	16 Basic Service 16 Service Exchange
2	D Class	2 Basic Service

Recommendations

No.	Type	Non-Compliance	Recommendation/New equipment
-----	------	----------------	------------------------------

Date of Issue:	12/02/2020
----------------	------------

The Certificate is to state that the firefighting equipment sited within the named premises has been inspected in accordance with BS5306-3:2017 or I.S 291:2015 Equivalent Testing and refilling completed will have been carried out in accordance with BS5306-9:2015 or I.S 291:2015 Equivalent. Siting of the firefighting equipment meets the requirements of BS5306-8:2012 or I.S 291:2015 Equivalent and any future amendments.

Remedial actions if not completed at the time of service will be noted below on this certification.