

Fire Suppression System maintenance certificate

Client

Site address

Almar Group Ltd
20 Seagoe Rd Craighaven

Responsible Person:	
Telephone number:	
Is there an O&M manual on site?	Yes / No
System location:	Main Kitchen
System size: 3 Gallon Tanks	2
System serial number:	5043320
System installation date:	overhaul 2015 2003
Is there a micro switch fitted?	Yes / No
If yes, what is it connected to?	Fire Alarm
Type of links:	360°
Number of links:	
Duct size:	
Canopy size:	
Number & type of duct nozzles:	Nozzle covers
2x2W /	2
Number & type of plenum nozzles:	Nozzle covers
3x1W /	3
Number & type of appliance nozzles:	Nozzle covers
2x1W / 1x1W	7
2x230 /	
2x245 /	
Appliances protected:	other
4x Salamander 2x6 ring range cooker x Griddle x single pan fryer	12 Stock Buena
1x bratt pan x ring range cooker x Chargrill	
1x Flat plate x table top fryer 3x twin pan fryer	
R102 Fire Suppression System maintenance - checklist	6 Month / 12 Month
1. Appliances are protected with correct nozzles	Yes / No
2. Duct / Plenum covered with correct nozzles	Yes / No
3. All nozzles positioned correctly	Yes / No
4. Cartridge weight checked	Yes / No
5. Test fire from terminal link	Yes / No
6. Test fire from remote actuator	Yes / No
7. Test micro switch	Yes / No
8. Nozzles clean	Yes / No
9. Nozzles covers in place (replace annually)	Yes / No
10. Fusible links replaced	Yes / No
11. Piping securely bracketed	Yes / No
12. All filters replaced	Yes / No

Customers Signature

Print Name.....

Responsible person

Date

Fire Technician