

Fire Suppression System maintenance certificate

Client	ALMAC
Site address	Seagor Craighen

Responsible Person:	
Telephone number:	
Is there an O&M manual on site?	
System location:	ALMAC House Seagor
System size:	3 Gallon Tanks
System serial number:	2
System installation date:	5043320
Is there a micro switch fitted?	2003 (Retir 2015)
If yes, what is it connected to?	Yes/No
Type of links:	Fire Alarm
Number of links:	360°F
Duct size:	4
Canopy size:	
Number & type of duct nozzles:	
2 x 2W	Nozzle covers
	2
Number & type of plenum nozzles:	
3 x 1W	Nozzle covers
	3
Number & type of appliance nozzles:	
3 x 1W	Nozzle covers
2 x 230	
2 x 245	7
Appliances protected:	
1 x Salamander 2 x 6 ring range cooker	x Griddle 3 x single pan fryer
1 x bratt pan	x ring range cooker
1 x Flat plate	x table top fryer
	x Chargrill
	x twin pan fryer
R102 Fire Suppression System 6 monthly maintenance - checklist	
1. Appliances are protected with correct nozzles	Yes / No
2. Duct / Plenum covered with correct nozzles	Yes / No
3. All nozzles positioned correctly	Yes / No
4. Cartridge weight checked	Yes / No
5. Test fire from terminal link	Yes / No
6. Test fire from remote actuator	Yes / No
7. Test micro switch	Yes / No
8. Nozzles clean	Yes / No
9. Nozzles covers in place (replace annually)	Yes / No
10. Fusible links replaced	Yes / No
11. Piping securely bracketed	Yes / No
12. All filters replaced	Yes / No

Customers Signature

Responsible person

Date 06/04/18

Print Name Colin Bickelstaff

Fire Technician