

CERTIFICATE OF MAINTENANCE

FIRE EQUIPMENT

PREMISES	Almac Sciences B 23 A Breagh Drive Seagoe Industrial Estate Craigavon BT63 5QD Northern Ireland
ENGINEER	Paul English
CERTIFICATE NUMBER:	C-00278

Quantity	Model	Details
9	Foam	2 Extended Service 7 Basic Service
10	CO2	9 Basic Service 1 Overhaul
3	Fire Blanket	3 Basic Service

Recommendations

No.	Type	Non-Compliance	Recommendation/New equipment
Date of Issue:		13/02/2020	

The Certificate is to state that the firefighting equipment sited within the named premises has been inspected in accordance with BS5306-3:2017 or I.S 291:2015 Equivalent Testing and refilling completed will have been carried out in accordance with BS5306-9:2015 or I.S 291:2015 Equivalent. Siting of the firefighting equipment meets the requirements of BS5306-8:2012 or I.S 291:2015 Equivalent and any future amendments.

Remedial actions if not completed at the time of service will be noted below on this certification.