

CERTIFICATE OF MAINTENANCE

FIRE EQUIPMENT

PREMISES	Almac Sciences B3 20 Seagoe Industrial Estate Craigavon BT63 5QD Northern Ireland
ENGINEER	Colin Bickerstaff
CERTIFICATE NUMBER:	C-00388

Quantity	Model	Details
9	Powder	3 Service Exchange 5 Basic Service
14	Foam	10 Basic Service 1 Extended Service 3 Condemned and replaced
13	CO2	8 Basic Service 3 Overhaul
5	Fire Blanket	4 Basic Service 1 Condemned and replaced

Recommendations

No.	Type	Non-Compliance	Recommendation/New equipment
ACOE015	Building 3 main Entrance	20 years old	Replaced with new
ACOE020	Back Door To Warehouse	20 years old	Replaced with new
ACOE024	lab 2	20 years old	Replaced with new
ACOE027	Lab 2	Damaged	Replaced with new

Date of Issue:	05/05/2020
----------------	------------

The Certificate is to state that the firefighting equipment sited within the named premises has been inspected in accordance with BS5306-3:2017 or I.S 291:2015 Equivalent Testing and refilling completed will have been carried out in accordance with BS5306-9:2015 or I.S 291:2015 Equivalent. Siting of the firefighting equipment meets the requirements of BS5306-8:2012 or I.S 291:2015 Equivalent and any future amendments.

Remedial actions if not completed at the time of service will be noted below on this certification.