

Fire Extinguisher Certificate of Inspection

Customer Name & Address	Almac Group - Almac Sciences B3 20 Seagoe Industrial Estate BT63 5QD				
Engineer:	Paul English	Job Number:	J-05085	Order Number:	
Certificate Number:	1288	Date:	12/04/2021		

Quantity	Model	Details
9	Powder	7 Basic Service
14	Foam	14 Basic Service
13	CO2	12 Basic Service
5	Fire Blanket	5 Basic Service
0	Water	
0	F Class	

Extinguisher	Serial No.	Location	Type	Size	Action
001 - Powder - Box O/S warehouse	ACOE001	Box O/S warehouse	Powder	9	Basic Service
002 - Foam - GMP Front Warehouse Main	ACOE002	GMP Front Warehouse Main	Foam	9	Basic Service
003 - CO2 - warehouse Office	ACOE003	warehouse Office	CO2	2	Basic Service
004 - Foam - Warehouse office	ACOE004	Warehouse office	Foam	6	Basic Service
005 - Foam - GMP Rear warehouse Main Entrance	ACOE005	GMP Rear warehouse Main Entrance	Foam	9	Basic Service
006 - Foam - NON- GMP Warehouse Back Entrance	ACOE006	NON- GMP Warehouse Back Entrance	Foam	9	Basic Service
007 - Foam - Non - GMP Warehouse Back Entrance	ACOE007	Non - GMP Warehouse Back Entrance	Foam	6	Basic Service
008 - CO2 - Warehouse @ Charger	ACOE008	Warehouse @ Charger	CO2	2	Basic Service
009 - Foam - Radio Chemistry Facility Entrance	ACOE009	Radio Chemistry Facility Entrance	Foam	6	Basic Service
010 - CO2 - O/S Comms Room	ACOE010	O/S Comms Room	CO2	2	Basic Service
011 - Powder - Lab 3	ACOE011	Lab 3	Powder	6	Basic Service
012 - Foam - Lab 3	ACOE012	Lab 3	Foam	6	Basic Service
013 - CO2 - Lab 3	ACOE013	Lab 3	CO2	2	Basic Service
014 - Fire Blanket - LAB 3	ACOE014	LAB 3	Fire Blanket	0	Basic Service
015 - Foam - Building 3 main Entrance	ACOE015	Building 3 main Entrance	Foam	6	Basic Service
016 - Foam - office Area	ACOE016	office Area	Foam	6	Basic Service
017 - CO2 - Office Area	ACOE017	Office Area	CO2	2	Basic Service
018 - CO2 - Office Area	ACOE018	Office Area	CO2	2	Overhaul
019 - CO2 - Back Door to Warehouse	ACOE019	Back Door to Warehouse	CO2	2	Basic Service
020 - Foam - Back Door To Warehouse	ACOE020	Back Door To Warehouse	Foam	6	Basic Service
021 - CO2 - Tea Room	ACOE021	Tea Room	CO2	2	Basic Service
022 - Fire Blanket - Tea Room	ACOE022	Tea Room	Fire Blanket	0	Basic Service
023 - Foam - Corridor F/Exit	ACOE023	Corridor F/Exit	Foam	6	Basic Service
024 - Foam - lab 2	ACOE024	lab 2	Foam	6	Basic Service

025 - Powder - Lab 2	ACOE025	Lab 2	Powder	6	Basic Service
026 - CO2 - Lab 2	ACOE026	Lab 2	CO2	2	Basic Service
027 - Fire Blanket - Lab 2	ACOE027	Lab 2	Fire Blanket	0	Basic Service
028 - Foam - Lab 3- ISOCHEM	ACOE028	Lab 3- ISOCHEM	Foam	6	Basic Service
029 - Powder - LAB 3 ISOCHEM	ACOE029	LAB 3 ISOCHEM	Powder	6	Basic Service
030 - CO2 - Lab 3 - ISOCHEM	ACOE030	Lab 3 - ISOCHEM	CO2	2	Basic Service
031 - Fire Blanket - Lab 3 - ISOCHEM	ACOE031	Lab 3 - ISOCHEM	Fire Blanket	0	Basic Service
032 - Foam - Manufacturing Finishing Suite	ACOE032	Manufacturing Finishing Suite	Foam	6	Basic Service
033 - CO2 - Manufacturing Finishing Suite	ACOE033	Manufacturing Finishing Suite	CO2	2	Basic Service
034 - Powder - Manufacturing Finishing Suite	ACOE034	Manufacturing Finishing Suite	Powder	6	Basic Service
035 - Fire Blanket - Manufacturing Finishing Suite	ACOE035	Manufacturing Finishing Suite	Fire Blanket	0	Basic Service
036 - CO2 - Humidity Block Door 1	ACOE036	Humidity Block Door 1	CO2	2	Basic Service
037 - Powder - Box @ Liquid Sampling Area	ACOE037	Box @ Liquid Sampling Area	Powder	6	Service Exchange
038 - Powder - Bax @ Liquid Sampling Area	ACOE038	Bax @ Liquid Sampling Area	Powder	6	Service Exchange
039 - Powder - Cabinet at new plant room	ACOE039	Cabinet at new plant room	Powder	9	Basic Service
040 - Powder - Cabinet at new plant room	ACOE040	Cabinet at new plant room	Powder	9	Basic Service
041 - CO2 - GMP warehouse at fire exit	ACOE041	GMP warehouse at fire exit	CO2	5	Basic Service

General Comments

Special Remarks

I/We have inspected and serviced as necessary to BS5306-3 (UK) and IS 291 (ROI), the fire extinguishers on this certificate. These were left in good working order, except where indicated on this certificate. Please Note Comments Listed Under Special Remarks.

Customer Signature:		Inspector's Signature:		Time In:	09:00
Customer Print Name:	David Emerson	Print Name:	Paul English	Time Out	12:10
Position:	Manager				

FIREHØW

FireHow Limited

Suite 10 Avonmore House

15 Church Square

Banbridge BT32 4AP

t 028406 48444 m 44 07846633129

e: colin.bickerstaff@firehow.co.uk

w: www.firehow.co.uk

Company Registration No. NI 648838

VAT No. 280425024

Photos

