

Fire Extinguisher Certificate of Inspection

Customer Name & Address	Almac Group - Almac Sciences U29 20 Seagoe Industrial Estate BT63 5QD				
Engineer:	Paul English	Job Number:	J-05086	Order Number:	
Certificate Number:	1289	Date:	02/06/2021		



Quantity	Model	Details
2	Powder	2 Basic Service
3	Foam	2 Basic Service 1 Extended Service
2	CO2	2 Basic Service
1	Fire Blanket	1 Basic Service
0	Water	
0	F Class	

Extinguisher	Serial No.	Location	Type	Size	Action
001 - Fire Blanket - Tea Room	AU29001	Tea Room	Fire Blanket	0	Basic Service
002 - Foam - O/S Dispatch	AU29002	O/S Dispatch	Foam	9	Extended Service
003 - CO2 - O/S Dispatch	AU29003	O/S Dispatch	CO2	5	Basic Service
004 - CO2 - 1st Floor	AU29004	1st Floor	CO2	2	Basic Service
005 - Foam - Goods In - Roller Door	AU29005	Goods In - Roller Door	Foam	6	Basic Service
006 - Powder - Rear Yard In Box	AU29006	Rear Yard In Box	Powder	6	Basic Service
007 - Powder - Rear Yard In Box	AU29007	Rear Yard In Box	Powder	6	Basic Service
008 - Foam - 1st floor	AU29008	1st floor	Foam	6	Basic Service

General Comments

Special Remarks

I/We have inspected and serviced as necessary to BS5306-3 (Uk) and IS 291 (ROI), the fire extinguishers on this certificate. These were left in good working order, except where indicated on this certificate. Please Note Comments Listed Under Special Remarks.

Customer Signature:		Inspector's Signature:		Time In:	10:45
Customer Print Name:	David Emerson	Print Name:	Paul English	Time Out	11:10
Position:	Manager				

FIREHØW

FireHow Limited

Suite 10 Avonmore House

15 Church Square

Banbridge BT32 4AP

t 028406 48444 m 44 07846633129

e: colin.bickerstaff@firehow.co.uk

w: www.firehow.co.uk

Company Registration No. NI 648838

VAT No. 280425024

Photos

